



COUNTY OF ALBEMARLE
Department of Community Development
401 McIntire Road, Room 227
Charlottesville, Virginia 22902-4596

Phone (434) 296-5832

Fax (434) 972-4126

Building Permit # _____

Early Service Permit # _____

Residential Early Electrical Service Agreement

Pending compliance with the Terms stated below (either Option #1 or Option #2) the Building Official will authorize electrical service to the referenced structure.

Option #1 - The service may be energized prior to ‘the electrical rough-in inspection, or at the time of the electrical rough—in inspection.
Comply with Terms 1, 2, 3 and 4.

Option #2 - The service may be energized after the rough—in inspection, but prior to the final electrical inspection. Comply with Terms 2, 3, 5 and 6.

Terms

1. Only the following items may be energized:
 - a. One 110 volt receptacle, on a dedicated circuit and GFCI protected.
 - b. One 220 volt receptacle, on a dedicated circuit and GFCI protected.
 - c. Any circuitry dedicated to heating/cooling equipment.
2. The meter, load—side conductors and all grounding shall be installed.
3. The service panel shall be installed in a dry location, or shall have a rain—tight enclosure; and shall have a permanent cover securely installed whenever the panel is unattended.
4. No circuit breakers, or fuseholders, other than those listed in Term #1, shall be installed.
5. Any or all devices may be installed. Any wires connected to the service panel, but not to a device, shall be securely taped or wire—nuttred off.
6. Gypsum board, or other approved ceiling and wall covering, must be installed.

Violation of any of these Terms may result in termination of the electrical service without notification. It is a violation of the Virginia Uniform Statewide Building Code to occupy or use a structure prior to the issuance of a certificate of Occupancy by the Building Official.

I, the undersigned, have read this Agreement in its entirety.

Owner/Agent

Date